

GAS SERVICE-LINE INSTALLATION RECORD



This Box for Orwell Gas use Only	
Date Received	
<input type="checkbox"/>	<input type="checkbox"/>
Accepted	Denied
Notes:	

Instructions:

- 1) Fill out the applicable sections of this form.
- 2) For a complete approved materials list & requirement details
Call 1-800-832-6164 or www.orwellgas.com
- 3) Fax completed form to (440) 437-1001

Customer Name			Service Line Installation Date		
Street Address			Sublot #		
City	State	Zip Code	County		
Building Type:			Minimum Test Pressure	Service Line Depth	
Residential	Commercial	Mobile Home	YELLOW PE2406 - 1" to 1.25"	This service line	
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		
Customer Service Line(Curb to Meter)			120 psig for 10 min.	was installed with an	
Material			YELLOW PE2406 - 2" to 6"	approved tracer wire	
Size			<input type="checkbox"/>		
<input type="checkbox"/> Plastic	Depth _____ ft.	<input type="checkbox"/> 1/2"	<input type="checkbox"/>	120 psig for 30 min.	not in contact with the
<input type="checkbox"/> Steel	Length _____ ft.	<input type="checkbox"/> 1"	BLACK PE3408 - 1" to 1.25"	<input type="checkbox"/>	pipe and both installed
		<input type="checkbox"/> 1.25"	<input type="checkbox"/>	<input type="checkbox"/>	to a minimum depth
		<input type="checkbox"/> 2"	BLACK PE3408 - 2" to 6"	<input type="checkbox"/>	of 18 inches.
		<input type="checkbox"/> Other: _____	<input type="checkbox"/>	<input type="checkbox"/>	
			<input type="checkbox"/>	160 psig for 30 min.	INITIALS:
Test Gauge Calibration Date			Actual Test Pressure and Duration		

***Service lines shall be installed with 3 ft. clearance from other lines using clean backfill (no rocks/sharp objects)
 ***Service lines and risers are to be installed in the location pre-determined by **Orwell Natural Gas**.
 ***OUPS must be contacted at least 48 hours prior to excavation at 1-800-362-2764.
 ***Only APPROVED MATERIALS can be used in service line installations.
 Approved materials include: Driscopex, Performance, Charter Plastics, Flying W, ENDOT, Oil Creek or Central Plastics pipe 1"CTS PE 2406 .099 W ASTM D2513Tracer wire 12 gauge solid copper with THHN or THWN coating***Perfection Servisert#71200 1"CTS .099W X 1" N.P.T. with 9"offset Perfection Bracket.

Installed and Tested By (Signature)	Print Name
Date Qualified For Plastic Joining	Date Qualified For Service Line Installation
Qualified By (Qualifying Agency, i.e. UTI)	OQ ID Number
Installing Company Name	Phone Number

By signing this form, the installer confirms that they installed the service line in accordance with applicable codes and standards. They also confirm that they were qualified under an approved Operator Qualification Program, in accordance with DOT requirements under 49 CFR 192, Subpart N. The installer is solely responsible for any work performed. If necessary, the installer also confirms they follow the drug and alcohol regulations of 49 CFR 199 which requires personnel be randomly tested for prohibited drugs and alcohol.
 By Signing this form, the installer confirms they made the joint(s) on the service line according to qualification standards and using approved Orwell Natural Gas materials.